

**MAINE WATER COMPANY
CAMDEN ROCKLAND DIVISION
PWSID ME0090300**

COMPLIANCE REPORTING PERIOD: **JUN-SEP 2019**

90TH%ILE LEAD RESULT: **3.1 ppb**

90TH%ILE COPPER RESULT: **0.104 mg/L**

IS THE SYSTEM IN COMPLIANCE: **YES**

NUMBER OF SAMPLES COLLECTED: **31**

Definitions:

- ND = Not Detected
- mg/L = milligrams per liter
- ppb = parts per billion
- 90th %ile =

REPORTED RESULTS	
LEAD ppb	COPPER mg/L
6.9	0.407
5.2	0.106
4.5	0.105
3.1	0.104
2.8	0.092
2.6	0.078
2.1	0.072
1.4	0.072
1.3	0.066
1.1	0.063
ND	0.060
ND	0.055
ND	0.055
ND	0.049
ND	0.043
ND	0.041
ND	0.039
ND	0.039
ND	0.038
ND	0.037
ND	0.036
ND	0.036
ND	0.034
ND	0.032
ND	0.031
ND	0.028
ND	0.027
ND	0.027
ND	0.017
ND	0.014
ND	0.010

in order of highest value to lowest

The Lead and Copper Rule is a United States federal regulation which limits the concentration of lead and copper allowed in public drinking water at the consumer's tap, as well as limiting the permissible amount of pipe corrosion occurring due to the water itself.

There is no maximum contaminant level for lead or copper. However, if your lead and copper tap monitoring results are higher than the action level of 15 ppb and/or the copper action level of 1.3 mg/L, corrosion control treatment is required of the public water system. To determine whether an action level has been exceeded, the value at the 90th percentile of all lead and copper samples collected is compared against the respective action level. This means that no more than 10 percent of your samples can be above either action level.