

**MAINE WATER COMPANY
SKOWHEGAN DIVISION
ME0091450**

COMPLIANCE REPORTING PERIOD: **JUN-SEP 2020**

90TH%ILE LEAD RESULT: **5.8 ppb**

90TH%ILE COPPER RESULT: **0.21 mg/L**

IS THE SYSTEM IN COMPLIANCE: **YES**

NUMBER OF SAMPLES COLLECTED: **20**

REPORTED RESULTS	
LEAD ppb	COPPER mg/L
37.1	0.32
6.7	0.25
5.8	0.21
3.6	0.19
3.3	0.18
3.0	0.16
2.6	0.12
1.8	0.10
1.8	0.09
1.7	0.08
1.6	0.08
1.4	0.06
1.4	0.06
1.1	0.06
1.1	0.05
1.0	0.05
<1	0.05
<1	0.04
<1	0.02
<1	0.01

in order of highest value to lowest

The Lead and Copper Rule is a United States federal regulation which limits the concentration of lead and copper drinking water at the consumer's tap, as well as limiting the permissible amount of pipe corrosion occurring due

There is no maximum contaminant level for lead or copper. However, if your lead and copper tap monitoring results exceed the action level of 15 ppb and/or the copper action level of 1.3 mg/L, corrosion control treatment is required. To determine whether an action level has been exceeded, the value at the 90th percentile of all lead and copper compared against the respective action level. This means that no more than 10 percent of your samples can be

er allowed in public
to the water itself.

esults are higher than
the public water system.
r samples collected is
above either action level.