

**MAINE WATER COMPANY
CAMDEN ROCKLAND DIVISION
PWSID ME0090300**

COMPLIANCE REPORTING PERIOD: **JUL-DEC 2022**

90TH%ILE LEAD RESULT: **4.2 ppb**

90TH%ILE COPPER RESULT: **0.0546 mg/L**

IS THE SYSTEM IN COMPLIANCE: **YES**

NUMBER OF SAMPLES COLLECTED: **73**

REPORTED RESULTS		
LEAD ppb	COPPER mg/L	
40.4	0.269	73
17.8	0.137	72
13.1	0.127	71
9.8	0.0967	70
6.1	0.0866	69
5.6	0.0835	68
4.6	0.0815	67
4.3	0.0553	66
3.7	0.0481	65
3.4	0.0473	64
3.1	0.0465	63
3	0.0414	
2.7	0.0406	
2.7	0.0358	
1.9	0.0354	
1.8	0.0352	
1.5	0.0329	
1.3	0.0308	
1.3	0.0286	
1.0	0.0285	
1.0	0.0285	
1.0	0.0280	
<1	0.0272	
<1	0.0269	
<1	0.0254	
<1	0.0251	
<1	0.0245	
<1	0.0238	
<1	0.0226	
<1	0.0225	
<1	0.021	
<1	0.0209	
<1	0.0202	
<1	0.0192	
<1	0.0191	
<1	0.0181	
<1	0.0181	
<1	0.0179	
<1	0.0174	
<1	0.0169	
<1	0.0165	
<1	0.0161	
<1	0.0160	
<1	0.0159	
<1	0.0154	
<1	0.0152	
<1	0.0142	
<1	0.0141	
<1	0.0137	
<1	0.0135	
<1	0.0122	
<1	0.0120	
<1	0.0119	
<1	0.0117	
<1	0.0112	
<1	0.0110	
<1	0.0101	
<1	0.0100	
<1	0.0096	
<1	0.0094	
<1	0.0093	
<1	0.0091	
<1	0.0089	
<1	0.0084	
<1	0.0082	
<1	0.0081	
<1	0.0074	

<1	0.0070
<1	0.0061
<1	0.0054
<1	0.0033
<1	0.0029
<1	<0.001

Results in order of highest value to lowest of samples taken at customer homes.

The Lead and Copper Rule is a United States federal regulation which limits the concentration of lead and copper allowed in public drinking water at the consumer's tap, as well as limiting the permissible amount of pipe corrosion occurring due to the water itself. There is no maximum contaminant level for lead or copper. However, if your lead and copper tap monitoring results are higher than the action level of 15 ppb and/or the copper action level of 1.3 mg/L, corrosion control treatment is required of the public water system. To determine whether an action level has been exceeded, the value at the 90th percentile of all lead and copper samples collected is compared against the respective action level. This means that no more than 10 percent of your samples can be above either action level.